

# Implementation of Ammonia Criteria

Patrick Ducey

Nebraska Department of Environment and Energy (NDEE)


# Final Aquatic Life Ambient Water Quality Criteria for Ammonia

- ▶ Freshwater ammonia criteria implemented in Federal Register August 22, 2013
- ▶ Passed in Nebraska Title 117 on December 13, 2014
- ▶ NDEQ/NDEE began to include the new criteria in NPDES permits in spring 2015
- ▶ September 2019 - Majority of Nebraska permittees with the potential to discharge ammonia have implemented the new criteria in their permit



# Why Implement the Ammonia Criteria?

- ▶ Protect aquatic biota, particularly freshwater mussels (*Musculium*, *Lampsilis*, *Villosa*) - Aquatic surveys are crucial for implementation



# Final 2013 ALC Criteria

## 2013 FINAL ALC CRITERIA FOR AMMONIA

(Magnitude, Frequency, and Duration)

(mg TAN/L)  
pH 7.0, T=20 °C

Acute (1-hour average) .....	17
Chronic (30-day rolling average) ....	*1.9

\* Not to exceed 2.5 times the CCC as a 4-day average within the 30-days, i.e. 4.8 mg TAN/L at pH 7 and 20 °C more than once in 3 years on average.

Criteria frequency: Not to be exceeded more than once in 3 years on average.

- ▶ TAN - total ammonia nitrogen
- ▶ CMC - criterion maximum concentration - acute criterion
- ▶ CCC - criterion continuous concentration - chronic criterion

# Nebraska - Site-Specific Criteria

- ▶ 40 CFR Part 131.11(b)(1)(ii) - allows for site-specific conditions
- ▶ Nebraska has warmwater and coldwater criteria (coldwater <25 °C)
- ▶ CW Acute - One Hour Average Concentration - Based on 1Q10 Conditions

003.03A Total Ammonia (as nitrogen).

003.03A1 One-hour average concentration in mg/l not to exceed the numerical value given by

$$AV = \text{Minimum of } \left\{ \left( \frac{0.275}{1 + 10^{7.204 - pH}} + \frac{39.0}{1 + 10^{pH - 7.204}} \right), \text{ or} \right. \\ \left. 0.7249 \left( \frac{0.0114}{1 + 10^{7.204 - pH}} + \frac{1.6181}{1 + 10^{pH - 7.204}} \right) (23.12 \times 10^{0.036(20 - \text{Temp})}) \right\}$$

where Temp is °C

- ▶ CW Chronic - Thirty-Day Average Concentration - Based on 30Q5 Conditions

003.03A2 Thirty-day average concentration in mg/l not to exceed the numerical value given by

$$CV = 0.8876 \left( \frac{0.0278}{1 + 10^{7.688 - pH}} + \frac{1.1994}{1 + 10^{pH - 7.688}} \right) (2.126 \times 10^{0.028 \times (20 - \text{Maximum of } \{ \text{Temp}, \text{ or } 7 \})})$$

where Temp is °C

# Acute Warmwater Criteria

003.04A1 One-hour average concentration in mg/l not to exceed the numerical value given by

$$AV = 0.7249 \left( \frac{0.0114}{1 + 10^{7.204 - pH}} + \frac{1.6181}{1 + 10^{pH - 7.204}} \right) \times \text{Minimum of } \{51.93, \text{ or } 23.12(10^{0.036(20 - Temp)})\}$$

where Temp is °C

ONE-HOUR AVERAGE CRITERIA FOR TOTAL AMMONIA (mg/l)  
Warmwater Aquatic Life Use Classes

Temperature (°C)	pH												
	6.6	6.8	7.0	7.2	7.4	7.6	7.8	8.0	8.2	8.4	8.6	8.8	9.0
0.0	48.86	43.80	37.65	30.81	23.96	17.77	12.66	8.77	5.97	4.05	2.77	1.92	1.38
2.0	48.86	43.80	37.65	30.81	23.96	17.77	12.66	8.77	5.97	4.05	2.77	1.92	1.38
4.0	48.86	43.80	37.65	30.81	23.96	17.77	12.66	8.77	5.97	4.05	2.77	1.92	1.38
6.0	48.86	43.80	37.65	30.81	23.96	17.77	12.66	8.77	5.97	4.05	2.77	1.92	1.38
8.0	48.86	43.80	37.65	30.81	23.96	17.77	12.66	8.77	5.97	4.05	2.77	1.92	1.38
10.0	48.86	43.80	37.65	30.81	23.96	17.77	12.66	8.77	5.97	4.05	2.77	1.92	1.38
12.0	42.22	37.85	32.53	26.62	20.70	15.35	10.94	7.58	5.16	3.50	2.39	1.66	1.19
14.0	35.77	32.07	27.56	22.56	17.54	13.01	9.27	6.42	4.37	2.97	2.02	1.41	1.01
16.0	30.30	27.17	23.35	19.11	14.86	11.02	7.85	5.44	3.71	2.51	1.72	1.19	0.86
18.0	25.67	23.02	19.78	16.19	12.59	9.34	6.65	4.61	3.14	2.13	1.45	1.01	0.73
20.0	21.75	19.50	16.76	13.72	10.67	7.91	5.64	3.90	2.66	1.80	1.23	0.86	0.62
22.0	18.43	16.52	14.20	11.62	9.04	6.70	4.78	3.31	2.25	1.53	1.04	0.73	0.52
24.0	15.61	14.00	12.03	9.85	7.66	5.68	4.05	2.80	1.91	1.29	0.88	0.62	0.44
26.0	13.23	11.86	10.19	8.34	6.49	4.81	3.43	2.37	1.62	1.10	0.75	0.52	0.37
28.0	11.21	10.05	8.64	7.07	5.50	4.08	2.90	2.01	1.37	0.93	0.63	0.44	0.32
30.0	9.50	8.51	7.32	5.99	4.66	3.45	2.46	1.70	1.16	0.79	0.54	0.37	0.27

# Warmwater Chronic Criteria

003.04A2 Thirty-day average concentration in mg/l not to exceed the numerical value given by

$$CV = 0.8876 \left( \frac{0.0278}{1 + 10^{7.688 - pH}} + \frac{1.1994}{1 + 10^{pH - 7.688}} \right) (2.126 \times 10^{0.028 \times (20 - \text{Maximum of } \{Temp, \text{ or } 7\})})$$

where Temp is °C

003.04A2a The highest four-day average concentration within a thirty-day period shall not exceed 2.5 times the thirty-day criterion.

003.04A2b The following table shows thirty-day average criteria for total ammonia at various temperatures and pHs.

THIRTY-DAY AVERAGE CRITERIA FOR TOTAL AMMONIA (mg/l)  
Warmwater Aquatic Life Use Classes

Temperature (°C)	pH												
	6.6	6.8	7.0	7.2	7.4	7.6	7.8	8.0	8.2	8.4	8.6	8.8	9.0
0.0	4.85	4.65	4.36	3.98	3.49	2.94	2.35	1.80	1.32	0.95	0.68	0.49	0.36
2.0	4.85	4.65	4.36	3.98	3.49	2.94	2.35	1.80	1.32	0.95	0.68	0.49	0.36
4.0	4.85	4.65	4.36	3.98	3.49	2.94	2.35	1.80	1.32	0.95	0.68	0.49	0.36
6.0	4.85	4.65	4.36	3.98	3.49	2.94	2.35	1.80	1.32	0.95	0.68	0.49	0.36
8.0	4.54	4.36	4.09	3.73	3.28	2.75	2.20	1.68	1.24	0.89	0.64	0.46	0.34
10.0	3.99	3.83	3.60	3.28	2.88	2.42	1.94	1.48	1.09	0.78	0.56	0.40	0.30
12.0	3.51	3.37	3.16	2.88	2.53	2.13	1.70	1.30	0.96	0.69	0.49	0.35	0.26
14.0	3.09	2.96	2.78	2.53	2.23	1.87	1.50	1.14	0.84	0.61	0.43	0.31	0.23
16.0	2.71	2.60	2.44	2.23	1.96	1.64	1.32	1.01	0.74	0.53	0.38	0.27	0.20
18.0	2.38	2.29	2.15	1.96	1.72	1.44	1.16	0.88	0.65	0.47	0.33	0.24	0.18
20.0	2.10	2.01	1.89	1.72	1.51	1.27	1.02	0.78	0.57	0.41	0.29	0.21	0.16
22.0	1.84	1.77	1.66	1.51	1.33	1.12	0.89	0.68	0.50	0.36	0.26	0.19	0.14
24.0	1.62	1.55	1.46	1.33	1.17	0.98	0.79	0.60	0.44	0.32	0.23	0.16	0.12
26.0	1.42	1.37	1.28	1.17	1.03	0.86	0.69	0.53	0.39	0.28	0.20	0.14	0.11
28.0	1.25	1.20	1.13	1.03	0.90	0.76	0.61	0.46	0.34	0.25	0.18	0.13	0.09
30.0	1.10	1.05	0.99	0.90	0.79	0.67	0.53	0.41	0.30	0.22	0.15	0.11	0.08

# Creating Limits using the Ammonia ALC

- ▶ Every state develops limits differently
- ▶ Technical Support Document for Water Quality-based Toxics Control (TSD)
- ▶ Limits may be developed with:
  - ▶ End-of-pipe limits based on criteria
  - ▶ Wasteload allocations
  - ▶ Mixing zones
  - ▶ Dye studies
  - ▶ Software
    - ▶ CORMIX
    - ▶ OpenFOAM
    - ▶ Visual Plumes







# Nebraska Two Value Steady-State WLAs

Facility	Seward W/WTF			<b>Spring</b>		<b>Summer</b>		<b>Winter</b>		
Program ID	NE0023876			1q10 cfs	6.14		0.45		4.30	
Receiving Water	Plum Creek			7q10 cfs	8.90		0.91		5.48	
Segment	BB4-20600			30q5 cfs	10.96		3.93		8.05	
Stream Flow Source	Stream Calculation			Chronic NH3 background mg/L	0.1		0.12		0.05	
Confidence	Low			Acute NH3 background mg/L	0.564		0.221		0.193	
Background pollutant source	BB4-20800			Other Chronic background mg/L						
Confidence	Med			Other Acute background mg/L						
Effluent data source	ICIS			Effluent Median MGD	0.792		0.841		0.73	
Confidence	High			Effluent Median cfs	1.225		1.301		1.129	
		Known Stream Flow (cfs)	Known Average Velocity (ft/s)	Known Average Depth (ft)	Known Average Width (ft)	Stream Slope (ft/mile)	Ls/Lv	Chronic Mixing Zone to 5000 Ft?		
Receiving Stream Characteristics		5.46	0.65	0.7	12	6	1.5	N		
		<b>Spring</b>			<b>Summer</b>			<b>Winter</b>		
Chronic NH3 Criteria	Chronic NH3 WLA	% Stream	Chronic NH3 Criteria	Chronic NH3 WLA	% Stream	Chronic NH3 Criteria	Chronic NH3 WLA	% Stream		
0.984	<b>8.89</b>	<b>100.0</b>	0.978	<b>3.57</b>	<b>100.0</b>	2.759	<b>22.07</b>	<b>100.0</b>		
Acute NH3 Criteria	Acute NH3 WLA	%Stream	Acute NH3 Criteria	Acute NH3 WLA	% Stream	Acute NH3 WLA	Acute NH3 WLA	%Stream		
12.717	<b>39.37</b>	<b>43.8</b>	8.099	<b>9.46</b>	<b>50.00</b>	13.793	<b>34.08</b>	<b>39.2</b>		

# Nebraska Water Quality Limits

General Data			
Facility Name:	Seward WWTF		
Permit Number:	NE0023876		
Date:	3-Apr-18		
Permit Writer:	Patrick Ducey		
Receiving Stream:	Plum Creek		
Title 117 ID:	BB4-20600		
Aquatic Use:	WWB		
Pollutant of Concern:	NH3		
Coefficient of Variation (CV):			
Spring	0.729		
Summer	0.362		
Winter	1.274		
Samples/Month (N):	4		
Chronic (N) day average:	4		
Data from WLA Worksheet			
	Spring	Summer	Winter
Effluent Flow in cfs:	1.225	1.301	1.129
1q10 Stream Flow in cfs:	6.14	0.45	4.3
7q10 Stream Flow in cfs:	8.9	0.91	5.48
30q5 Stream Flow in cfs:	10.96	3.93	8.05
% 1q10 used for mixing:	43.776	50.000	39.182
% 7q10 used for mixing:	100.000	100.000	100.000
% 30q5 used for mixing:	100.000	100.000	100.000
Acute WLA:	39.37	9.46	34.08
Chronic WLA:	8.89	3.57	22.07
Calculated WLA Multipliers			
	Spring	Summer	Winter
acute WLA multiplier:	0.271	0.470	0.165
chronic WLA multiplier:	0.468	0.669	0.305
MDL LTA multiplier:	3.69	2.13	6.06
AML LTA multiplier:	1.68	1.32	2.20
Water Quality Based Permit Limit Calculations for:			
NH3			
	Spring	Summer	Winter
Acute WLA	39.37	9.46	34.08
Chronic WLA	8.89	3.57	22.07
Acute LTA	10.67	4.45	5.62
Chronic LTA	4.16	2.39	6.73
Concentration Based Permit Limits:			
<b>Maximum Daily (mg/L)</b>	<b>15.35</b>	<b>5.08</b>	<b>34.08</b>
<b>Average Monthly (mg/L)</b>	<b>6.99</b>	<b>3.16</b>	<b>12.38</b>
Mass Based Permit Limits:			
<b>Maximum Daily (kg/day)</b>	<b>46.02</b>	<b>16.17</b>	<b>94.17</b>
<b>Average Monthly (kg/day)</b>	<b>20.95</b>	<b>10.05</b>	<b>34.22</b>
Whole Effluent Toxicity Limits			
**Based on CV of 0.6			
	Spring	Summer	Winter
Acute WLA	0.96	0.35	0.75
Chronic WLA	8.26	1.70	5.85
Acute LTA	0.31	0.11	0.24
Chronic LTA	4.36	0.90	3.09
Acute Toxicity (TUa)	0.96	0.35	0.75
Chronic Toxicity (TUc)	13.57	2.79	9.61
Permit Limits:			
<b>Acute Toxicity (TUa)</b>	<b>1.00</b>	<b>1.00</b>	<b>1.00</b>

# CORMIX



CORMIX v11.0.0

Project Pages Pre-Processing Tools Run Output Data Reports Post-Processing/Advanced Help

Load Clear Save Save As Print lbs/kg SI-Units CorHyd CorSpy Validate & Run FC Tree CorVue CorJet FFL CorSens User Manual CorHelp

Project Effluent Ambient **Discharge** Mixing Zone Output Processing

Discharge Page

Discharge Geometry Data

CORMIX1 Single Port CORMIX2 Multiport **CORMIX3 Surface**

Buoyant Surface Discharge

Discharge located on: right bank

Discharge Configuration

Flush Protruding Co-flowing

Horizontal Angle SIGMA: 90 degrees

Bottom Slope: 0 degrees

Discharge Outlet

Channel Pipe

Width: 3 ft

Depth: 0.934 ft

Local Depth at Discharge Outlet: 1.009 ft

- ▶ Advantages: More accurate, limits are higher than steady-state but still protective of water quality
- ▶ Disadvantages: Cannot be used for very low flow and ephemeral streams

# Limits Implemented in Nebraska NPDES Permits


- ▶ Monitoring frequency dependent on effluent flow rate, compliance history for ammonia, reasonable potential
- ▶ Sample type dependent on type of facility
- ▶ Most facilities have been able to meet new limits

Table 2: Seasonal Discharge Limits and Monitoring Requirements						
Parameters	Storet #	Units	Discharge Limits		Monitoring Frequency	Sample Type
			Monthly Average	Daily Maximum		
Spring Ammonia (March 1 – May 31)	00610	mg/L	2.47	4.96	Weekly	24-Hour Composite
		kg/day	5.86	11.77		
Summer Ammonia (June 1 – Oct. 31)	00610	mg/L	1.99	3.99	Weekly	24-Hour Composite
		kg/day	4.66	9.35		
Winter Ammonia (Nov. 1 – Feb. 28 [29])	00610	mg/L	4.62	9.26	Weekly	24-Hour Composite
		kg/day	10.59	21.23		
Acute Toxicity <i>Ceriodaphnia sp</i>	61425	TU <sub>a</sub>	Report	1.00	Annually <sup>(a)</sup>	24-Hour Composite
Acute Toxicity <i>Pimephales promelas</i>	61427	TU <sub>a</sub>	Report	1.00	Annually <sup>(a)</sup>	24-Hour Composite

**Footnotes:**  
<sup>(a)</sup> Sampling shall be conducted seasonally. One year testing shall be conducted in spring, one in summer, one in winter, etc.  
**Abbreviations:** mg/L – milligrams per liter kg/day – kilograms per day TU<sub>a</sub> – acute toxic units

# Stream Impairments

- ▶ In Nebraska, the Wood River was designated as impaired by ammonia
- ▶ Ammonia ALC implementation for the Gibbon POTW addresses the impairment




# What if Facilities Cannot Meet Proposed Limits?

- ▶ Permitting Tools
  - ▶ Compliance Schedules - rules set forth in 40 CFR Part 122.47
  - ▶ More accurate data
  - ▶ Variances - Nebraska considering controlled discharge lagoon variance
- ▶ Facility improvements, new treatment technologies
- ▶ Other methods to meet ammonia ALC
  - ▶ Ceasing to discharge
  - ▶ Land application of treated effluent
  - ▶ Consent Orders


# New Technologies and Engineering

- ▶ Some municipalities need to construct new WWTFs to meet limits - expensive
- ▶ York Water Reclamation Facility - newest POTW in state - BNR
- ▶ Some POTWs installing diffusers to increase mixing



# Challenges to ALC Implementation - Data

- ▶ EPA permit writers do not have comprehensive access to state databases
- ▶ Lack of data (Temperature, pH, ammonia content, flow rate)
- ▶ Receiving stream flow might be difficult to determine
  - ▶ USGS gages - might not be available (Nebraska also has DNR gages)
  - ▶ StreamStats - not available in every state





# Changing River Conditions

- ▶ The ammonia criteria is dependent on temperature and pressure, what if those are changing?
- ▶ In Nebraska, the receiving stream is basis for chronic criteria, some facilities have limits based on the chronic criteria
- ▶ In many Nebraska streams, pH is increasing

Big Blue River - BB1-10000 Median pH		
2005-2008		
Spring	Summer	Winter
7.8	8.03	7.55
2011-2014		
Spring	Summer	Winter
8.5	8.5	7.93

- ▶ Temperature - Do states have data regarding changing temperatures? Higher temperature means lower criteria for facilities.

# Ammonia Residuals in Streams

- ▶ High background ammonia - from other point sources and non-point sources can create lower limits
- ▶ Example: Gering - Western Sugar - Scottsbluff



# Choosing Data - Background Ammonia



# Controlled Discharge Lagoon Facilities

- ▶ Have high pH (often over 9.0 standard units)
- ▶ Low ammonia limits
- ▶ Many facilities are encouraged to land apply
- ▶ Nebraska is looking into a variance for CDLs



# NPDES Permits

- ▶ 40 CFR Part 122.44 - Gives authority to establish limitations and standards
- ▶ Antidegradation and protection of beneficial uses is important tool to implement the ALC
- ▶ Use TMDLs if available
- ▶ Anti-backsliding can be useful for some facilities to maintain limits
  - ▶ Facilities may be exempt from anti-backsliding if they cannot meet the new limits
  - ▶ Exemptions may be useful for variances
  - ▶ New facilities may be exempt if proxy data is used

# Questions/Comments?

- ▶ What are your solutions to implementing the ammonia criteria?
- ▶ What if a facility cannot meet limits?

Patrick Ducey - 402-471-2188 - [patrick.ducey@nebraska.gov](mailto:patrick.ducey@nebraska.gov)